


Item	Description
1	Aerona ASHP
2	Flexible hose & isolation valve ¹
3	Isolation valve
4	Grant Volumiser *** (optional)
5	Anti-Vibration Mounts ²
6	Flow Sensor ¹
7	Grant Mag One magnetic filter kit ²
8	Wiring Centre ¹
9	Touchscreen Display ¹
10	Automatic air vent
11	Cylinder immersion heater
12	DHW cylinder
13	Immersion heater relay ²
14	Drain point
15	Removable filling loop ²
16	Double check valve
17	Pressure gauge ²
18	Expansion vessel ²
19	Tundish
20	Pressure relief valve ²
21	3-Port diverter valve ²
22	Thermostatic Mixing Valve
23	UFH Pump (Optional depending on system design)
24	UFH Manifold
25	Water Temperature Sensor ¹
26	Outdoor Weather Sensor ¹
27	UH8 Wiring Centre
28	Room thermostat (Grant NeoStat or Edge)


¹ Supplied with the HPIDR32SMART* Smart Controller Kit
^{*} Outputs available: 6, 10, 13 & 17 kW
² Supplied with HPIDR32PACKR



**Compression elbow c/w air vent (supplied with HPIDVOL30EXT6)



Scale: NTS
Paper Size: A3



IMPORTANT
For positions of the Flow (outlet) and Return (inlet) connections on HPID10R32BODY, HPID13R32BODY and HPID17R32BODY models, see above.

***** ! NOTE !**
***30L external volumiser is available as an optional component where there is insufficient system volume (HPIDVOLEXT30).

! NOTE !
Please refer to the Aerona ASHP installation instructions for details of the flow and return connections at the heat pump.

! NOTE !
For additional heater support from Grant External Volumiser, Refer to Grant Aerona Smart Controller installation manual and Schematics HPCS-BUHS and HPCS-BUHE.

! NOTE !
This system schematic should be read in conjunction with the Grant Aerona Smart Control installation instructions and wiring diagram HPCS-R002ER32.

Project Title: Grant Aerona Smart Controls Installation Pack R W-Plan Plus type system UFH (UH8 Controls) downstairs - Radiators upstairs HW priority & Legionella protection provided by Smart Controller (system schematic)	
Drawing Set: Aerona Smart Control System Schematics	Dwg. No: HPCS-R002SR32
Status: Approved	Revision: 0.4
Rev Date: 21/06/24	Drawn By: AC&DB
Checked By: NS	

This drawing and its content is subject to copyright. Use other than for its original intended purpose must be arranged with an employee of Grant UK Ltd. Frankland Road, Blagrove Industrial Estate, Swindon, SN5 8YG, tel: 01380 736920