



**ADDENDUM
to
INSTALLATION INSTRUCTIONS
for
All Grant QR2 Range Indirect
Heat Pump Cylinders**

**DOC 0216 - 1.1/01
DOC 0217 - 1.2/01
DOC 0218 - 1.1/01
Rev 00 - April 2026**

ATTENTION INSTALLER - UPDATED INFORMATION

The following information applies to the Installation Instructions for all the Grant QR2 range of heat pump cylinders.

Please read this Addendum carefully as this information **MUST** be used in conjunction with the corresponding sections indicated in this addendum for the installation & Operating Instruction manuals mentioned above.

After installation and commissioning any of the Grant QR2 range of cylinders, please ensure that both the installation & Operating instructions and this Addendum are left with the user for future reference.

Amendment affecting Intallation manuals DOC0216, DOC0217 & DOC0218 in following sections:

Table 2-4 - page 8 in DOC0216

Table 2-4 - page 8 in DOC0217

Table 2-2 - page 7 in DOC0218

Correction:

All 300 litres cylinders will be supplied with:

- 3/4" PTRV 7 bar/90°C - 15 mm compression fitting
- 22/28 mm Tundish